

Statement of Compliance

Redcare Complete PD6662: 2004

Redcare Complete is a fully managed, monitored, dedicated and duplicated end-to-end Alarm Transmission System (ATS) from the supervised premises interface, through the redcare network, and on to the Alarm Receiving Centre. **Redcare Complete** is suitable for Grade 2, 3 and 4* alarm installations.

This document provides redcare's Statement of Compliance for **Redcare Complete** when connected to the Redcare network under the scheme described in PD6662: 2004.

The ATS at the supervised premises complies with the requirements of PD6662: 2004 & Tables 10 and 11 of *prEN50131-1: 2004 as follows:

- **Redcare Complete** is compliant to Grade 2, Grade 3 and Grade 4*.
- **Redcare Complete** has a rating of ATS 5 on the primary (landline) path and a rating of ATS 4 on the secondary (radio) path, this becoming ATS 5 if the primary path is unavailable.
- **Redcare Complete** is suitable for use with BS8418 CCTV systems.

Product	Highest Notification Option	ATS Value	Environmental Class	I&HAS EN Grade
redcare Complete	4C	Primary ATS 5 D4/M4/T5/S2/I3/A4 Secondary ATS 4 D4/M4/T4/S2/I3/A4	I	Grade 4

CE Marking Directive: Redcare Complete complies with the following European Directives, where applicable:

73/23/EEC (Low Voltage Directives); EN60950 User Safety; EN41003 Network Safety 89/336/EEC (Electro Magnetic Compatibility Directive) as amended by 92/31/EEC; EN55022 Emissions Class B; EN50130-4 Immunity 99/5/EEC (Radio and Telecommunications Terminal Equipment Directive); EN50131-1: 2004 Security ATS Signalling to Grade 4. Enclosure to Grade 3*

*Enclosure provided is Grade 3, Grade 4 enclosures available on request.